

TAMIL NADU FIRE AND RESCUE SERVICE DEPARTMENT

FIRE SAFETY NO OBJECTION CERTIFICATE

LICENSE NO : 17/V/2023

DATE : 17.07.2023

**Parangipettai Fire and Rescue
Service Station**

**Sub: Fire and rescue service department - Cuddalore
Fire and Rescue Service Station for purpose of fire safety
No Objection Certificate - Reg.**

**Ref: 1. GO/MS 122 Dt.14.09.2004 / Dept of School Education, Tamil Nadu.
2. GO/MS 123 Dt: 14 .09.2004 / Dept of School Education , Tamil Nadu
3. Application from Correspondent / Principal / Head Master of
MUNA HI - TECH INTERNATIONAL SCHOOL (CBSE) Dt: 05.07.2023**

Fire Safety no Objection Certificate is hereby granted under section 13 of the Tamil Nadu fire Service Act, 1985 for constructed School Building at Ariyakosti village Panchayat, C.Pudhupettai . The building and premises comprises of G+1 owned/occupied by Muna Hi-Tech international School at Ariyakosti village , C.Pudhupettai Panchayat , which is comprised in R.S.No 54/2A,55/1, have complied with the fire prevention and fire safety requirements in accordance with rule of state fire Service Rules , and verified by Mr.K.Jayakumar ,The Station Officer, from Fire and Rescue Service Station - Parangipettai on 17.07.2023 in the presence of Mr.K.R.RAJKUMAR, Principal and that the school is granted Fire Safety No Objection Certificate for a period of one year from 17.07.2023 to 16.07.2024 subject to the conditions stated below.

CONDITIONS

1. THIS License is valid for one year month from the date of issue.
2. Fire Safety systems should be maintained in good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. A trained fire Service Person, preferably retired one should be appointed.
6. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.

ATTESTED BY

Signature of Station Officer


K. JAYACHANDRAN
ADVOCATE & NOTARY
Parangipettai
Cuddalore
Cell No. 94421 11111

- a). Building occupancy capacity should not be more than 4 people per sq. meter as per the National building Code – 2005.
- b). The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.
- c). As the Para 6.3 of the BIS Standards IS 14435:1997 as the classrooms have only one entrance, the capacity of the class rooms shall have to be limited to 45 students.
- d). Periodical maintenance and care should be taken to maintain all fire protection equipments.
- e). Mock drill has to be conducted at regular intervals in consultation with the District Officer, Fire and Rescue Services, Cuddalore.
- f). The classroom doors/ windows should be made of either non – combustible material or materials with high fire – resistance rating.
- h). The classroom doors / windows should be made of either non – combustible material or materials with high fire – resistance rating.
- i). The classroom doors/ windows shutters when opened should not obstruct movement along the exit or escape route.
- j). A class room shall have two entrances. One door with opening towards the teachers end and the other door on the other end of the class room with only a simple latch / tower bolt arrangement for locking from inside. This door shall not have any arrangement for locking from outside.
- k). The school shall have proper Evacuation Plan of action to rescue the children during any emergency in the school premises.
- l). All the floors should be provided Down Comer with Hose Reel system. (If the condition is not fulfilled within 3months the license will be automatically cancelled).
If here is any violation and deviation from the govt. Rule and Act the license issued will stand cancelled.

To:

The Principal,
Muna Hi-Tech international School,
Ariyakoshti Village, C.Pudhupettai Panchayat.

CC : District Officer , Cuddalore District.



ATTESTED BY ME

K. JAYACHANDRAN, B.Sc., B.L.,
ADVOCATE & NOTARY PUBLIC
Reg. No: 14244/19
PARANGIRETTAI - 608 502.
CUDDALORE DT.
Cell: 94864 55615

Handwritten signature and date: 2022
Handwritten text: கல்யாண அலுவலர்
அரியக்கோத்தி கிராம பஞ்சாயத்து நிர்வாகம்,
பரங்கிரைட்டை

NOTARISED TRANSLATION OF SEAL OF FIRE OFFICER

FROM TAMIL TO ENGLISH



DEPARTMENT OF
FIRE AND RESCUE SERVICES
PARANGIPETTAI-608502

நிலைய அலுவலர்
தீயணைப்பு மீட்பு பணிகள் திணையம்,
பரங்கிபேட்டை

STATION OFFICER
FIRE AND RESCUE SERVICES
PARANGIPETTAI




K. JAYACHANDRAN, B.Sc., B.L.,
ADVOCATE & NOTARY PUBLIC
Reg. No: 14244/19
PARANGIPETTAI - 608 502.
CUDDALORE DT.
Cell: 94864 55615